## **ENVIRONMENTAL IMPACT ASSESSMENT REPORT**

FOR

LARA SUPER THERMAL POWER PROJECT, STAGE-II (2 X 800 MW)

AT

ARMUDA, CHHAPORA, BODAJHARIA, DEVALSURA, MAHLOI, RIYAPALLI, LARA, JHILGITAR AND KANDARGH VILLAGES IN PUSSORE TALUK, RAIGARH DISTRICT, CHHATTISGARH

# **EXECUTIVE SUMMARY**

**Project Proponent** 



M/s. NTPC Limited, Noida (A Government of India Enterprise)



Vimta Labs Ltd. 142 IDA, Phase-II, Cherlapally Hyderabad–500 051 env@vimta.com, www.vimta.com

(NABL Accredited and ISO 17025 Certified Laboratory, Recognized by MoEF&CC, New Delhi)

February, 2019



## 1.0 EXECUTIVE SUMMARY

NTPC Limited (A Govt. of India Enterprise), is the largest power generating company in India. Government of India (GoI) set it up in November, 1975 with the objective of planning, promoting and organizing integrated development of thermal power in the country. In 1997, NTPC was conferred "Maharatna" status by GoI in 2010. NTPC is now emerging as a well-diversified company on its way of becoming an Integrated Power Major, having entered into hydro power, coal mining, power trading, equipment manufacturing, power distribution business and renewable energy generation. Company also plans to enter into nuclear power development.

NTPC Ltd is proposing for the expansion of existing Lara Super Thermal Power Project of 1600 MW (2x800 MW (Stage-I)) to 3200 MW by addition of 1600 MW (2 x 800 MW (Stage-II) which is located in Armuda, Chhapora, Bodajharia, Devalsura, Mahloi, Riyapalli, Lara, Jhilgitar and Kandagarh villages of Pussore C.D.block in Raigarh district of Chhattisgarh.

Lara Super Thermal Power Plant (STPP) Unit-I of 800 MW of stage-I has been commissioned on 23.03.2018 and Unit-II is in advance stage of commissioning.

## **1.1** Purpose of the Report

As per Environmental Impact Assessment EIA Notification dated 14<sup>th</sup> September, 2006, commissioning or operation of thermal power plants ( $\geq$ 500 MW) falls under category 'A' under project type-1(D) and requires prior Environmental Clearance (EC) to be obtained from MoEF&CC before the commencement of any ground activity.

In line with the said notification, TOR online application (Form-1 & Pre-feasibility report) for Environmental Clearance (EC) was filed to MOEF&CC on 24.09.2018 vide proposal no. IA/CG/THE/75138/2012 dated 20.07.2018. The Terms of Reference (TOR) was accorded by MOEF&CC vide letter dated F.No.J-13012/11/2018.IA.I(T) dated 29.10.2018. The draft Environmental Impact Assessment (EIA) report has been prepared based on the TOR accorded by MOEF&CC.

Vimta Labs Limited, Hyderabad, an accredited agency with Quality Council of India (QCI) / National Accreditation Board of Education and Training (NABET) vide registered no. NABET/EIA/1619/RA0049 dated 22.03.2017 is assigned to undertake an Environmental Impact Assessment (EIA) study and preparation of Environment Management Plan (EMP) on various environmental components, which may be affected due to the impacts arising out of the proposed thermal power plant.



## **1.2 Environmental Setting**

The project is located at villages Armuda, Chhapora, Bodajharia, Devalsura, Mahloi, Riyapalli, Lara, Jhilgitar and Kandagarh villages in Pussore taluk, Raigarh district, Chhattisgarh.

The project site is located in Chhattisgarh state. However, the 10 km radius study area falls in Chhattisgarh and Odisha states. 35 villages are falling in K. Lakhanpur C.D block from Jharsuguda district and Ambahona C.D block from Barghar district of Odisha in the 10 km study area.

The proposed main plant and township are located between the coordinates  $21^{\circ}44'57''$  N to  $21^{\circ}46'19''$  N and  $83^{\circ}25'37''$  E to  $83^{\circ}27'56''$  E. The coordinates of Stage-I ash pond are  $21^{\circ}43'7''$  N to  $21^{\circ}44'27''$  N and  $83^{\circ}27'37''$  E to  $83^{\circ}29'4''$  E.

The main plant, township, ash pond and other areas for proposed Lara STPP Stage-II (2  $\times$  800 MW) shall be accommodated in the land acquired for Lara STPP under Stage-I.

The topography of the project site is undulating. Elevation of the proposed thermal power plant ranges from 200 m to 210 m above Mean Sea Level (MSL) and the general slope is towards North to North East. The site involves 151.762 ha of forest land for which Stage-II forest clearance has been accorded by MOEF&CC. The nearest villages from the project site are Bodajharia (0.2 km, E), Chhapora (0.2 km, N) and Devalsura (0.3 km, W).

The interstate boundary of Chhattisgarh and Odisha is at a distance of about 1.5 km east from the project site. The nearest national highway is NH-200 which is about 0.7 km in direction of NE. The nearest railway station is Raigarh railway station at a distance of 14.5 km in NNW direction. The nearest airport is Raipur which is about 186.0 km at a distance of SW.

The nearest reserve forests from the project site are Gajmar R.F (4.0 km, NNE), Jharghan R.F (5.5 km, NE) and Holsari Dungri R.F (9.3 km, ESE). The nearest water bodies from the project site are Nala near Chhapora village- 50 m, Mahanadi river (7.6 km, South), Kelo river (1.4 km, E), Chotte Kelo river (7.7 km, NE), Sapnai nala (7.6 km, NE), Kur nala (7.9 km, NE) and Hirakud reservoir (12.0 km, east). There is no national park, no wildlife sanctuary located within 10 km of radius of plant site. The study area showing 10 km radius are shown in **Figure-1**.



DOC. NO: 9587/999/GOG/S/001 REV. NO.:0

ISSUE DATE: 18/01/2019

Page :ES -3



Plant Site Boundary 📩 Township Area 🗔 Ash Pond Area

FIGURE-1 STUDY AREA MAP (10 KM RADIUS)



## **1.3 Brief Description of Project**

## 1.3.1 Nature of the Project

Lara STPP, stage-II will be a coal based thermal power project based on super critical boiler parameters. The proposal involves construction and operation of two units of 800 MW each. The main components of the project include:

- Steam generator, turbine generator and auxiliary units;
- Coal handling system including dust extraction and suppression system;
- Air cooled condenser system ;
- Water & effluent treatment system;
- Fire protection system;
- Air conditioning & ventilation system;
- Electrostatic precipitators, NOx control and Flue Gas Desulphurisation (FGD) system;
- Chimney;
- Limestone and gypsum storage and disposal facilities;
- Ash handling system with dry ash extraction and wet mix system, storage and disposal facilities; and
- Electrical systems: Generator bus duct, transformers, switchgears, switch yard etc.

## **1.4 Salient Features**

The salient features of the proposed expansion of STPP are given in **Table-1**.

TABLE-1
SALIENT FEATURES OF PROPOSED EXPANSION OF STPP

Sr. No.	Particulars	Details
1	Stage- I	2 x 800 MW (In advanced stage of commissioning)
	Stage- II	2 x 800 MW (Present proposal)
2	Technology	Super critical
3	Total area of the plant	2400 acres. Proposed Lara STPP Stage-II (2x800 MW) shall be accommodated in the available land within the existing premises of Lara STPP
4	Fuel	Coal
А	Source of fuel	Talaipali Coal Block Mining Project (TLCMP) is linked to cater the coal requirement for Lara STPP. EC for TLCMP has already been accorded by MoEF&CC vide letter no. J-11015/279/2009-IA.II (M) dated 02.01.2013.
В	Fuel transportation	MGR/IR
C	Average fuel requirement (Coal)	7.0 MTPA with 90 % PLF
D	Average calorific value range	3000-3500 kcal/kg
E	Ash content	32-43 % (Max)
F	Sulphur content	0.5% (Max)



DOC.	NO:	9587,	/999/	GOG/	/S/001
------	-----	-------	-------	------	--------

REV. NO.:0

ISSUE DATE: 18/01/2019

Page :ES -5

5	Ash generation			
	Fly ash	2.32 MTPA		
	Bottom ash	0.58 MTPA		
	Total ash	2.90 MTPA		
6	Water requirement	Make up water requirement for Lara-II (2 x 80 MW) project would be 1680 m <sup>3</sup> /hr.		
		Chhattisgarh have accorded water availability confirmation of 45 MCM (5137 m <sup>3</sup> /hr) for stage-I (2 x 800 MW) power project and 68 MCM (7763 m <sup>3</sup> /hr) for stage-II for Lara STPP from Sardih barrage on river Mahanadi		
А	Source of water	Sardih barrage on river Mahanadi		
В	Cooling system	Air cooled condenser		
7	Power evacuation	The nearest 765/400 kV pooling station located to this project is Kotra pooling station in Raigarh. This pooling station is interconnected to other two pooling station in this vicinity i.e. Champa and Tamanar pooling station. Also Kotra pooling station is planned to be interconnected with Dhule (PG) thorough a high capacity +/- 600 kV HVDC corridor under common regional transmission system strengthening.		
8	Discharge	Zero Liquid Discharge		
9	Wastewater treatment	Proposed ETP & existing STP		
10	Fire fighting system	Adequate firefighting systems as per Tariff Advisory Committee (TAC) and OISD guidelines will be provided		
11	Total Project cost	Rs. 11,136 crores		

Source: NTPC

## **1.5** Resource Requirement

• Land Requirement

The land acquired for the project shall be mainly used for establishing main power house complex and township. Greenbelt will be developed wherever the vacant place is available. In addition, large scale afforestation and plantation activities shall be undertaken in and around main plant and township areas in all available spaces.

A total of 2400 acres of land has been acquired to accommodate plant, township and ash dyke of Lara STPP. Approximately 1620 acres land is under utilization for construction of Stage-I units, ancillary facilities, ash disposal area, township and remaining 780 acres shall be utilized for stage-II units.

## • Water Requirement & its Source

Make up water requirement for this project would be about 1680 m<sup>3</sup>/hr. The source of water for the project is from Saradih barrage on Mahanadi river at a distance of about 45 km from the plant site.



Coal

The coal requirement for the proposed expansion of 2 x 800 MW power plant shall be about 7.0 MTPA at 90 % PLF. The coal requirement shall be met from Talaipalli coal blocks allotted to NTPC. Mode of coal transportation from the coal mines to the power plant is by MGR/IR.

• Manpower Requirement

The proposed power plant will require skilled and semi-skilled personal during construction and operational phase. Many of the people from neighboring villages, as found suitable will get opportunity for indirect employment during construction and operational phase.

The total manpower from various agencies during construction of stage-II would be about 1000 and during operation period is estimated to be about 500.

• Power Requirement & Source

The requirement of the construction power supply for the project would be met from the Lara Stage-I. 11 KV miscellaneous switchgear located near Stage-I 400 KV switchyard.

## **1.6 Process Description**

In a thermal power plant, the chemical energy of the fuel (coal) is first converted into thermal energy (during combustion), which is then converted into mechanical energy (through a turbine) and finally into electrical energy (through a generator). It has the following steps:

- The coal is transferred from the coal handling plant by conveyor belt to the coal bunkers, from where it is fed to the pulverizing mills, which grind it to fine powder. The finely powdered coal, mixed with air is then blown into the boiler by a fan where it burns like a gas;
- The process of combustion releases thermal energy from coal. The boiler walls are lined with boiler tubes containing high quality de-mineralized water (known as boiler feed water). The combustion heat is absorbed by the boiler tubes and the heat converts the boiler feed water into steam at high pressure and temperature. The steam, discharged through nozzles on the turbine blades, makes the turbine to rotate, which in turn rotates the generator coupled to the end of the turbine. Rotation of generator produces electricity, which is passed to the step-up transformer to increase its voltage so that it can be transmitted efficiently. The power is evacuated via switchyard through a transmission system;
- During combustion, the non-combustible part of coal is converted into ash. A small part of ash (about 20%) binds together to form lumps, which fall into the ash pits at the bottom of the furnace. This part of ash, known as bottom ash is water quenched, ground and then conveyed to pits for subsequent disposal to ash disposal area or sale;



- Major part of the ash (about 80%) is in fine powder form, known as fly ash, and is carried out of the boiler along with the flue gas. The flue gas, after heat recovery, is passed through the electrostatic precipitators, where the ash is trapped by electrodes charged with high voltage electricity;
- The flue gases exiting from the Electrostatic Precipitators (ESPs) shall be treated in Flue Gas De-sulphurisation (FGD) system and discharged through a tall chimney for wider dispersal of remaining ash particles and gases. The ash collected in the ESP hoppers is extracted in dry form and conveyed to dry ash storage silos from where it is supplied to user industries;
- Any unused part of fly ash is mixed with water and conveyed to ash disposal area in a slurry form; and
- The steam, after passing through the turbines, is condensed back into water in air cooled condensers and the same is re-used as a boiler feed water for making steam.

## **1.7** Baseline Environmental Status

The baseline data monitoring studies have been carried out for three months from  $1^{st}$  October 2018 to  $31^{st}$  December 2018 representing post monsoon & part of winter season. The baseline studies are in progress to cover the remaining seasons.

The project site is located in Chhattisgarh state. However, the 10 km radius study area falls in Chhattisgarh and Odisha states. Hence, the baseline monitoring locations for ambient air quality, noise, soil and ecology are covered in both states of Chhattisgarh and Odisha. The following villages considered for baseline monitoring falls in the state of Odisha are Dipapara, Karlabahal, Kanaktura, Lubabaga, Amapali, Charpalli, Semilia and Chhattisgarh are Chhapora, Rengalpali, Kandagarh, Jhilgitar, Lohakhan, Kondpali, Tarda, Nawapara, Mahadbatha, Riyapali and Lara.

## 1.7.1 <u>Meteorology</u>

The meteorological parameters were recorded on hourly basis during the study period and comprises of parameters like wind speed, wind direction (from 0 to 360 degrees), temperature, relative humidity, atmospheric pressure, rainfall and cloud cover. The meteorological parameters have been recorded and are presented in **Table-2**.

TABLE-2
SUMMARY OF THE METEOROLOGICAL DATA GENERATED AT SITE

Month	Temperature (°C)		Relative Humidity (%)		Rainfall (mm)
	Max	Min	Max	Min	
October 2018	33	20	74	61	0
November 2018	30	18	65	54	0
December 2018	29	17	62	49	0
Range	17.0	-33.0	49.0-2	74.0	0

The maximum and minimum temperatures recorded at site during study period were 33.0  $^{\rm 0}C$  and 17.0  $^{\rm o}C$ . The relative humidity was observed to range from 49 %



– 74 % during the study period. Predominant winds are mostly from NE followed by NW. Calm conditions prevailed for 16.4 % of the total time.

## 1.7.2 Ambient Air Quality

Twelve ambient air quality locations were monitored in and around project site. The minimum and maximum concentrations for  $PM_{10}$  were recorded as 27.1 µg/m<sup>3</sup> and 66.2 µg/m<sup>3</sup>. The minimum and maximum concentrations for  $PM_{2.5}$  were recorded as 14.3 µg/m<sup>3</sup> and 28.0 µg/m<sup>3</sup>. The minimum and maximum SO<sub>2</sub> concentrations were recorded as 8.6 µg/m<sup>3</sup> and 17.9 µg/m<sup>3</sup>.The minimum and maximum NO<sub>2</sub> concentrations were recorded as 10.1 µg/m<sup>3</sup> and 20.4 µg/m<sup>3</sup>.

The concentrations of  $PM_{2.5}$ ,  $PM_{10}$ ,  $SO_2$ ,  $NO_2$ ,  $O_3$ , CO,  $NH_3$ , Pb, Hg, BaP, As, Ni and  $C_6H_6$  are observed to be well within the NAAQ standards prescribed by Central Pollution Control Board (CPCB) for industrial and rural /residential zone.

The concentration can be attributed due to local industrial activities of the NTPC power plant and also due to rural activities and traffic. There are no other major industrial activities in the study area.

## 1.7.3 Land Use

As per satellite imagery, the built-up land is 7.7 %, forest land occupies 7.7 %, agricultural land is about 53.3 %, water body is 14.2 % and remaining land is either area available for cultivation or cultivable waste land.

#### 1.7.4 Soil Characteristics

The pH of the soil in the study area ranged from 6.06 to 7.48. The electrical conductivity was observed to be in the range of 82.4  $\mu$ mhos/cm to 259  $\mu$ mhos/cm. The nitrogen values range between 41.3 to 128.2 kg/ha. The phosphorus values range between 35.6 to 217.9 kg/ha. The potassium values range between 127.2 to 384.1 kg/ha. The chlorides were found to be in the range of 95.7 to 271.1 mg/kg of soil. The analysis of soil samples does not indicate any external industrial contamination.

#### 1.7.5 <u>Water Quality</u>

The baseline water quality status in the region is established by analysing samples at 13 locations consisting of seven ground water samples and six surface water samples. The ground and surface water samples were analysed and found that ground water quality is well within the drinking water quality limits.

#### Surface Water Quality

The pH value was observed to be in the range of 6.79 to 8.5 which are well within the specified standards of 6.5 to 8.5. Electrical conductivity of surface water samples was observed to be in the range of 215  $\mu$ S/cm to 1252  $\mu$ S/cm. The dissolved oxygen was observed in the range of 4.8 mg/l to 5.8 mg/l. The total



DOC. NO: 9587/999/GOG/S/001		
REV. NO.:0		
ISSUE DATE: 18/01/2019		
Page :ES -9		

hardness was found to be in the range of 48.7 mg/l to 337.3 mg/l. The chloride concentration was observed in the range of 17.8 mg/l to 177.6 mg/l and the sulphates were found to be in the range of 9.5 mg/l to 71.5 mg/l. Fluoride content was found to be in the range of 0.3 mg/l to 1.0 mg/l. Cyanides and phenolic compounds found to be below detection limits. Bacteriological studies revealed that the total coliform count is measured 380-1124 MPN/100ml. The surface water quality in the study area does not indicate any industrial contamination.

## Ground Water Quality

The pH in range of 5.86 -7.63 which are well within the specified standard limits of 6.5 to 8.5. Color and turbidity of the samples ranged from 1-7 Hazens and 1-5 NTU respectively. Electrical conductivity of the samples ranged from 270-857 µS/cm. The total hardness of the samples ranged from 58.3-332.5 mg/l. Calcium and magnesium concentrations ranged from 15.4-84.6 mg/l and 4.8-32.7 mg/l. The total dissolved solids of the samples ranged from 173 -545 mg/l. Range of chlorides and sulphates concentrations at all the locations 24.2-78.2 mg/l and 6.2-92.5 mg/l respectively. Fluoride concentration ranged from 0.3-1.0 mg/l and is found to be within the permissible limits. Similarly, nitrates are also found to be ranging in between 1.6- 10.2 mg/l. Iron concentration in ground water varied from 0.01-0.61 mg/l. Zinc levels varied from 0.01 mg/l to 2.91 mg/l. Aluminium concentration in ground water is 0.13-1.84 mg/l which are within the limits stipulated. All other metal concentrations are observed to be below detectable limits. The total coliform counts are <2 in all the samples against the standard limit of 10 MPN/100 ml. The ground water quality in the study area does not indicate any industrial contamination.

#### 1.7.6 Noise Levels

The noise monitoring has been conducted for determination of noise levels at fifteen locations in the study area. The day time noise levels at all the locations were ranged in between 43.3 dB(A) 51.2 dB(A). The night time noise levels were ranged in between 39.4 to 47.6 dB (A).

Noise monitoring results reveal ambient noise levels in all the locations are well within the limits as per CPCB ambient noise standards. The higher range can be attributed to local industrial and commercial activities.

#### 1.7.7 Flora and Fauna

The fauna in the buffer zone is confined in the respective schedules of the Wildlife (Protection) Act, 1972 such as Schedule –II, III, IV and V. Due to anthropogenic interventions and mining interests in the district, green cover and conservation areas are fragmented.

There are no endangered aquatic fauna found in the Kelo river and in the Mahanandi river in the 10 km radius of the buffer zone, especially fishes of the 10 km radius study area. Apparently also there is no presence of endangered & threatened flora as per the list of "Botanical Survey of India".



## **1.8** Anticipated Environmental Impacts and Mitigation Measures

#### 1.8.1 Impact on Land Use

The land selected for proposed expansion of power plant project is within the premises of STPP, which is categorized as industrial area. There will not be any change in land use. There will not be any additional land acquisition for the expansion project. Hence, there is no impact on land use due to the proposed expansion.

There is no additional ash pond for Stage-II expansion project. The ash pond for stage-I will be used for Stage-II also. The present land use of the area falls under industrial category. The project site will not be having any adverse impact on the surrounding land use during the operation period.

#### 1.8.2 Impact on Soil

The impact on soil during operation of the project could result due to deposition of residual particulate matter and gaseous emissions on the soil. The soil within the deposition zone of pollutants may undergo physico-chemical changes due to deposition of PM (ash particles) and washout of gases (SO<sub>2</sub> and NO<sub>2</sub>) during the rains. The impacts on soil due to operation of the power plant and gaseous emission are likely to be negligible as the incremental concentration of particulate matter (PM), SO<sub>2</sub> & NO<sub>2</sub> levels are observed within limit.

#### 1.8.3 Impact on Air Quality

The major air pollutants from a power project are Particulate Matter (PM),  $SO_2$ ,  $NO_2$  and CO which are emitted continuously from the stacks (point sources), attached with coal combustion boilers. The fugitive emissions of coal dust are also contributed by coal handling activities at storage yard, wind erosion, spillages from conveyor system, pulverization etc.

Prediction of impacts on air environment has been carried out employing mathematical model based on a steady state Gaussian plume dispersion model. The incremental concentrations of the proposed project are super imposed on the maximum baseline data to arrive at resultant concentrations during operational phase of the proposed project. The comparisons between two scenario's resultant concentrations are given in **Table-3**.



DOC. NO: 9587/999/GOG/S/001 REV. NO.:0 ISSUE DATE: 18/01/2019 Page :ES -11

## TABLE-3 RESULTANT CONCENTRATION

	Maximun	n Concentratio	ns (µg/m³)	Posultant		
	Incremental			Resultant		
Pollutant, (µg/m³)	Maximum Baseline, (µg/m <sup>3</sup> ) in Study area	Single Two Stacks Stack height of Height of 150m with 220 m with Single Flue Bi-flue each (µg/m <sup>3</sup> ) (µg/m <sup>3</sup> )		Single Stack Height of 220 m with Bi- Flue (µg/m³)	Two stacks Height of 150m with Single Flue Each (μg/m <sup>3</sup> )	
PM <sub>10</sub>	66.2	0.91	1.27	67.11	67.47	
SO <sub>2</sub>	17.9	3.0	4.2	20.9	22.1	
NO <sub>x</sub>	20.4	3.0	4.2	23.4	24.6	

The incremental concentrations when superimposed over the existing maximum baseline concentrations, the resultant concentrations are observed to be within the permissible levels for residential/rural conditions.

The mitigative measures recommended for control of air pollution in the plant are:

- Installation of ESP of efficiency more than 99.90% to limit the particulate matter (PM) concentrations below 30 mg/Nm<sup>3</sup>;
- Installation of flue gas de-sulfurization (FGD) system;
- Combustion control for NO<sub>x</sub> (Low NO<sub>x</sub> burner);
- Provision of twin/single flue stack of 220/150 m height for wider dispersion of gaseous emissions;
- Online flue gas monitors as well as flue gas flow rates and temperature measurement shall be provided for all stacks;
- Dust suppression and extraction system in coal handling plant;
- Provision of water sprinkling system at raw material storage yard; and
- Asphalting of the roads within the plant area.

#### 1.8.4 Impact on Water Resources

#### > Water Resources

Make up water requirement for this project would be about 1680 m<sup>3</sup>/hr. Lara STPP will abstract its entire water requirement from the Saradih Barrage being created on river Mahanadi by Government of Chhattisgarh.

DM plant discharge shall be treated in neutralization pit to adjust pH prior to using in ash handling unit. Since there will be no effluent discharge from proposed project, the impact on water quality of surrounding water bodies will be insignificant.



## > Impact on Ground Water

As no ground water is proposed to be used for plant during operation phase, there will be no impact on availability of ground water during operation of plant.

> Impact on Hydrology

The storage at Saradih barrage is confined within banks and therefore it shall not cause any submergence of land beyond the banks. The river carries sufficient flow during monsoon season.

Therefore drawl of water for Lara STPP during monsoon season shall have no adverse impact on downstream water users. Lean season flow in the river shall not be obstructed. Surplus water in monsoon season shall be ponded at Saradih barrage to meet lean season water requirement for Lara STPP. Thus, in lean season also there shall be no adverse impact on downstream water users.

It may be concluded that the withdrawal of water for Lara STPP Stage-II, shall not cause any major adverse impact on the availability of water to downstream users.

## Water Pollution Mitigation Measures

An effluent management scheme, consisting of collection, treatment, recirculation and disposal of effluents shall be implemented in order to optimize the makeup water requirement as well as liquid effluent generation. The detail of water system for the project is described as follows:

- The filter backwash water of PT plant shall be collected and recycled back to the DM clarifier;
- The sludge from clarifiers of water PT plant shall be collected in a sump/ pit and shall be pumped to bottom ash slurry sump for disposal to bottom ash dyke;
- The waste effluents from neutralization pits of DM plant and condensate polishing plant shall be collected in the respective neutralization pits and neutralized before pumping to the ash slurry sump before final disposal;
- A coal settling pond shall be provided to remove coal particles from coal handling plant waste. Decanted water shall be pumped back to the coal dust suppression system;
- Service water effluent collected from plant drains shall be led to a sump. From the sump the service water shall be pumped upto tube settler/ clarifier for treatment of suspended solids. Treated service water shall be sent back to service water tank to the extent possible for re-use;
- All the plant liquid effluents shall be mixed in Central Monitoring Basin (CMB) and finally to ETP/Recycling point;



- The plant shall have two different systems for ash disposal conventional wet ash slurry disposal system with Ash Water Recirculation System (AWRS) for Bottom Ash and High Concentration Slurry Disposal System (HCSD) for fly ash. HSCD system will require less quantity of water and there will be no effluent from the fly ash disposal site;
- Efficient operation of various treatment schemes shall be ensured so that the quality of treated effluent from CMB conforms to relevant standards, prescribed by regulatory agencies. The treated effluents shall be recycled/reused to the existing plant water system; and
- The sewage from plant and township shall be treated in a sewage treatment plant. The treated effluent conforming to prescribed standards shall be utilized for plantation to the extent possible.

## 1.8.5 Impact of Solid Waste

Ash generated due to combustion of coal will be the main industrial/ solid waste generated from the project. About 80% of the ash shall be generated as fly ash while 20 % of the ash shall be generated as bottom ash. With average annual coal requirement of 7.0 MTPA and average 43 % ash in coal, it is estimated that about 2.9 MTPA of ash shall be generated annually.

In addition, gypsum shall be generated as solid waste from FGD system, which shall be utilized/ disposed off in an environmentally suitable manner. The details of the solid waste generated in the plant are given in **Table-4**.

Sr. No.	Plant	Quantity	Mode of Disposal
1	Ash generation Fly ash Bottom ash Total ash	2.32 MTPA 0.58 MTPA 2.90 MTPA	Ash will be supplied to cement industries. In case the ash could not be lifted, the same will be disposed in ash pond using HCSD disposal method.
2	Gypsum Generation	1300 tonnes /day	Byproduct used by cement industries

#### TABLE-4 EXPECTED SOLID WASTE FROM THE PROPOSED EXPANSION PROJECT

#### 1.8.6 Impact on Noise Levels

The main sources of noise and vibration during operations will be:

- Delivery of equipment and raw materials by trucks;
- Transfer of coal through railway line;
- Operation of generators and turbine inside the power house; and
- Operation of various pumps, fans and motors.

Scheduling deliveries to daytime as much as possible would minimize noise generation by truck movement. Turbines, transformers, compressors, pumps, vehicles and miscellaneous equipment during plant operation, will generate noise.



However, proper acoustic enclosures would be provided to control the noise level within 80dB, as per the requirement of Occupational Safety and Health Administration Standard (OSHA).

#### Noise Pollution Mitigation Measures

In the process, various equipment's like pumps, compressors and boilers etc will generate the noise. Greenbelt, landscaping with horticulture at power block areas to reduce noise impacts is already being implemented. The recommendations to mitigate higher noise levels are:

Equipments should be designed to conform to noise levels prescribed by regulatory authorities:

- > Provision of acoustic barriers or shelters in noisy work places;
- Provision of hoods to noise generating equipments like pumps;
- Provision of thick greenbelt to attenuate the noise levels; and
- Provision of personal protective equipment (PPE) such as earplugs, earmuffs to the workers working in high noise level area.

#### 1.8.7 Impacts on Socio-Economics

The requirement of unskilled manpower will be met from nearby villages during construction phase. The project will also help in generation of the indirect employment apart from direct employment. This will be a positive socio-economic development for the region. There will be a general upliftment of standard of living in the region.

#### **1.9 Environmental Monitoring Program**

Post project environmental monitoring is important in terms of evaluating the performance of pollution control equipment installed in the project. The sampling and analysis of the environmental attributes will be as per the guidelines of CPCB/ Chhattisgarh Environment Conversation Board (CECB). The frequency of air, noise, surface water and ground water sampling and location of sampling being as per the directives of CECB.

#### **1.10** Risk Assessment and Disaster Management Plan

Risk assessment has been carried out to quantify the extent of damage and suggest recommendations for safety improvement for the proposed expansion project. Risk mitigation measures based on consequence analysis and engineering judgments are incorporated in order to improve overall system safety and mitigate the effects of major accidents.

An effective Disaster Management Plan (DMP) to mitigate the risks involved is in place for proposed expansion of power plant. This plan defines the responsibilities and resources available to respond to the different types of emergencies envisaged. Training exercises will be held to ensure that all personnel are familiar with their responsibilities and that communication links are functioning effectively.



## **1.11 Project Benefits**

The beneficial impact of proposed expansion project on the civic amenities will be substantial after the commencement of project activities. As corporate social will responsibility various activities be started like welfare for poor/widows/physically challenged persons. Capacity building programs, sports events, assistance to government schools, scholarships will be done. For community development trainings will be provided for woman for self employment, community toilets, drinking water facilities etc. A separate budget will be made for these activities during operation of plant. Medical camps/health awareness camp will be organized in nearby villages for both the states of Chattisgarh and Odisha.

## **1.12** Environmental Cost

An Environmental cost provision of Rs. 2147.77 crores has been kept towards the environmental control measures.

## 1.13 Conclusions

The proposed expansion project would add significant value to Indian economy. The project will not only help ensure our country by becoming self-sufficient in terms of power generation, but will also drive macro-economic growth.

The proposed expansion project would have minimal impacts on the environment. However, with proper and judicious implementation of the mitigation and environment management measures, the impacts can be further minimized and can be maintained well within the permissible limits specified by the regulatory authorities.

Thus, it can be concluded that with the strict implementation of the pollution control and mitigation measures, with proper environment management system in place the proposed expansion project will be beneficial to the society and will contribute to the economic development of the state in particular and the country in general.